

RAVEN ANALYTICAL LABORATORY

104 1/2 First Street PO Box 807
Roscommon, MI 48653
Phone: 989-275-4790

Fax: 989-275-4899
EPA Certified Laboratory No. 9954

Laboratory Report

Sample #: 211013-25 WSSN/Source SINGLE FAMILY DWEL
System Name/owner: Dustin Sawmiller
Collection Address 1234 Fair Winds Drive Ossineke MI 49766
Township/County Alpena
Date Collected 10/12/2021 4:00 PM Collected By Fair Winds Home Inspections
Sampling Pt KITCHEN Purpose REAL ESTATE TRANSACTION

Copy sent to FAIRWINDSINSPECTIONS@GMAIL.COM

ANALYTE	MAXIMUM LIMIT	TEST	DETECTION LIMIT	RESULT
Nitrate as N	10.0 mg/L	**TNT835	0.5 mgL	ND
Nitrite as N	1.00 mg/L	**4500N02B	0.015mg/L	ND
Date/Time of Analysis:	10/14/2021	8:50 AM		

E. Coli	0 PER 100ml	ReadyCult	P/A*	ND
Total Coliforms	0 PER 100ml	ReadyCult	P/A*	POSITIVE

Date/Time Analysis Begins: 10/13/2021 3:15 PM Date/Time Analysis Ends: 10/14/2021 3:15 PM
*=ReadyCult ND = Not Detected/Water is Potable P/A = Presence/Absence

The analyses performed by Raven Analytical Laboratories were conducted using methods approved by the U.S Environmental Protection Agency in accordance with the Safe Drinking Act and other regulatory agencies as appropriate. To be tested under EPA Regulations for Nitrate/Nitrite samples must be recieved at 4 degrees celsius + or - 2 degrees celsius.

*Coliform bacteria detected in this water sample. WATER IS NOT SAFE TO DRINK. Retest as soon as possible It is recommended that the well be chlorinated and resampled.

Read and Understood by:

Anthony Blizzard, Water Technician

Carrie Brumm, Office Manager

Today's date

10/15/2021